

ENGINEERS =

PLANNERS

LAND SURVEYORS

FOUAD K. DAOUD, P.E. & S.E., PRESIDENT & CEO PENNY L. SCHMITZ, EXEC. VICE PRES., COO & CFO RICK G. ENGSTROM, C.E.T., VICE PRESIDENT MICHAEL A. ZELINSKAS, P.E., VICE PRESIDENT WILLIAM K. ANGERMAN, P.E., VICE PRESIDENT

July 29, 2009

1412 6th STREET SW P.O. BOX 1467 MASON CITY, IA 50402-1467 phone 641-423-8271 fax 641-423-8450 e-mail: masoncity@whks.com website: www.whks.com

Mr. William Stangler, Operations and Maintenance Manager City of Mason City 10 First Street NW Mason City, IA 50401-3224

RE:

Equipment Storage Facility

Mason City, Iowa

Dear Bill:

This letter serves as verification that the proposed Equipment Storage Facility for the City of Mason City will meet the current state building energy code, as required for the I-JOBS Local Infrastructure Program application. The proposed structure will be a pre-fabricated insulated metal building with a radiant tube heating system. This structure is proposed to have a total volume greater than 100,000 cubic feet, and therefore will need an architect/engineer review for energy efficiency per Chapter 303 of the current State Building Code. We intend to include the architect/engineer review and certification as part of the requirements for the project's Contract Documents, to be completed by either the installation contractor or the building manufacturer.

We do not intend to require that the proposed Equipment Storage Facility meet current Energy Star standards, due to the proposed building being primarily for vehicle and equipment storage and that minimal occupancy by City employees is expected.

Please contact me if you have any questions.

Sincerely,

WHKS & Co.

William K. Angerman, P.E.

WKA/kg

Enclosures

cc: Beth Enright, City of Mason City

Fouad Daoud, WHKS & Co.

Mason City\6708.01\FEMA Modifications\I-JOBS Building\Energy Standards Letter 7-29-09.doc